Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791 or by visiting their website at https://www.epa. gov/ground-water-and-drinking-water/safedrinking- water-hotline.

HOUSEHOLD TIPS FOR PROTECTING OUR DRINKING WATER SUPPLY

- · Limit your use of chemicals, fertilizers, pesticides, and other hazardous products. Buy only what you need reducing the amount to be later discarded. Be sure to follow label directions.
- · Check your car, boat, motorcycle, and other machinery for leaks and spills. Collect leaks with a drip pan until repairs can be made. Clean up spills by absorbing the spill Do not rinse with water or allow spills to soak into the ground.
- · Recycle used oil, automotive fluids, batteries, and other chemical products. Do not dispose of these hazardous products in toilets. storm drains, wastewater systems, creeks, alleys or the ground. These actions pollute the water supply.
- · If you have a septic system, have it inspected and serviced every three years.
- · Plug abandoned wells on your property as these old wells provide a direct route for surface contamination to reach groundwater supplies. Contact a licensed well driller for assistance.
- · For more information on recycling and hazardous waste disposal in Wayne County. visit the Wayne Union Recycle (WUR) Soil and Water Conservation District's website at http://waste-not.org/recycling-drop-offs/.

SPECIAL PRECAUTIONS

Sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

If present, elevated levels of lead can cause serious health problems. Especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Cambridge City Water Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water testing methods and steps you can take to minimize expo- sure is available from the Safe Water Hotline or Drinking https://www.epa.gov/ground-water-and-drinkingwater/basic-information-about-lead-drinkingwater.

Some people may be more vulnerable to contaminants in drinking water than the general population Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ trans- plants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC quidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

US POSTAGE PERMIT NO CAMBRIDGE OF 47327

Annual **Drinking** Water Quality Report



Cambridge City Water Works Cambridge City, Indiana

Cambridge City Water Works is pleased to present this year's Drinking Water Quality Report. This report is designed to keep you informed about the quality of your drinking water over the past year. Our goal is to provide you, the customer, with a safe and dependable supply of drinking water.

SOURCE WATER ASSESSMENT AND WELLHEAD PROTECTION

A Source Water Assessment has been completed for our community. The source of Cambridge City's drinking water is groundwater produced from three wells located within the community. The wells withdraw drinking water from a sand and gravel aguifer. A Source Water Assessment has indicated that the drinking water sys- tem has a moderately high susceptibility to contamination.

To help protect our water supply wells, Cambridge City Water Works has implemented a Wellhead Protection Plan that focuses on public awareness, education, spill prevention, and reporting. Information on what you can do to help protect our drinking water supply is included in this report.

If you have any questions concerning your water utility or this report, please contact Mr. Ken Risch at (765) 478-5611. If you would like additional information, you are welcome to attend one of our regularly scheduled Town Council Meetings held at the City Building (127 North Foote Street). Meetings are held on the second Monday of each month at 6:00PM. We encourage you to participate and give us feedback.

AMBRIDGE CITY WATER WORKS 7 NORTH FOOTE STREET MBRIDGE CITY, IN 47327

Revised Total Coliform Rule (RTCR)

The Revised Total Coliform Rule (RTCR) seeks to prevent waterborne diseases caused by E. coli. E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the

 Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE, MINOR (RTCR)	11/01/2022		We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure
			of the quality of our drinking water during the period indicated.

DEFINITIONS

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Below the Detection Limit (BDL) - Substance not detected in the sample.

Maximum Contaminant Level (MCL) – The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated substances, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Maximum Contaminant Level Goal (MCLG) - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) -The highest level of disinfectant allowed in drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG) — The level of drinking water disinfectant allowed in drinking water.

Not Applicable (N/A) - No MCLG or MCL has been established for these unregulated substances.

Parts Per Billion (PPB) - One part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

Parts Per Million (PPM) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

The State allows us to monitor for some substances less than once per year because the concentrations of these substances do not change frequently. Therefore, some of our data, while representative, is more than one year old.

TABLE NOTES

(1) - The maximum levels detected for Copper and Lead represents the 90th percentile value as calculated from a total of 10 samples.

AVERAGE WATER QUALITY DATA FOR 2022

The Cambridge City Water Works routinely monitors for substances in your drinking water according to all Federal and State laws. The following table provides the results from our most recent monitoring.

Name of Substance	Date Sampled	Violati on Yes/No	Maximum Level Detected	Range of Levels Detected	Unit Measurement	MCLG	MCL	Likely Source of Substance in Drinking Water
Disinfected Substances	5							
Chlorine Residual	2022	No	0. 62	0.10 to .62	PPM	MRDLG =4	MRDL =4	Water additive used to contro microbes.
HAA5s (Haloacetic acids)	2022	No	1.0	1.45 – 1.45	РРВ	No goal for the Total	60	By-product of drinking water disinfection.
TTHMs (Trihalomethanes)	2022	No	4.0	3.63 – 3.63	PPB	No goal for the total	80	By-product of drinking water disinfection.
Inorganic Substances								
Barium	9/20/21	No	0.16	0.16 to 0.16	PPM	2	2	Erosion of natural deposits.
Copper	9/15/20	No	.19(1)	0.003 to 0.37	PPM	1.3	AL=1. 3	Corrosion of household plumbing systems and erosion of natural deposits.
Fluoride	2021	No	0.6	0.66 to 0.66	PPM	4	4	Water additive which promot strong teeth.
Fluoride (adjusted)	9/25/15	No	0.687	0.687 to 0.687	PPM	4	4	Water additive which promot strong teeth.
Lead	9/11/20	No	3.6(1)	0.3 to 2.6	PPB	0	AL=15	Corrosion of household plumbing systems and erosion of natural deposits.
Nitrate	2022	No	2.0	1.74 to 1.74	PPM	10	10	Erosion of natural deposits, runoff from fertilizer use, leaching from septic tanks and sewage.
Sodium	9/25/15	No	23.2	23.2 to 23.2	PPM	N/A	N/A	Erosion of natural deposits ar urban runoff.
Radioactive Contamin	ants							
Gross Alpha excluding radon & uranium	9/18/19	No	2.4	2.4 – 2.4	pCi/L	0	15	Erosion of natural deposits

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources, such as agriculture, storm water runoff, and residential uses.
- Organic chemicals, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive materials, which can be naturally occurring or be the result of oil and gas production and mining activities.